



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Bainbridge-Guilford Central School District

Project Name: Guilford Water Lead Testing

Howard Thompson
18 Juliard St.
Bainbridge, NY 13733

Project / PO Number: 27466
Received: 05/13/2016 08:40
Reported: 05/20/2016 12:28

Analytical Testing Parameters

Client Sample ID: Faculty Room, First Draw
Lab Sample ID: J6E0776-01
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0425

Analytical Testing Parameters

Client Sample ID: Faculty Room, 30 Seconds
Lab Sample ID: J6E0776-02
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1224

Analytical Testing Parameters

Client Sample ID: Fountain, Main Entrance, First Draw
Lab Sample ID: J6E0776-03
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1238



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Fountain, Main Entrance, 30 Seconds
Lab Sample ID: J6E0776-04
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1241

Analytical Testing Parameters

Client Sample ID: Nurse #1, First Draw
Lab Sample ID: J6E0776-05
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1245

Analytical Testing Parameters

Client Sample ID: Nurse #1, 30 Seconds
Lab Sample ID: J6E0776-06
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1248



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Nurse #2, First Draw
Lab Sample ID: J6E0776-07
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1252

Analytical Testing Parameters

Client Sample ID: Nurse #2, 30 Seconds
Lab Sample ID: J6E0776-08
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1302

Analytical Testing Parameters

Client Sample ID: Cafeteria Fountain, First Draw
Lab Sample ID: J6E0776-09
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00193, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1306



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Cafeteria Fountain, 30 Seconds
Lab Sample ID: J6E0776-10
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00313, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1309

Analytical Testing Parameters

Client Sample ID: Kitchen Faucet, First Draw
Lab Sample ID: J6E0776-11
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00106, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1313

Analytical Testing Parameters

Client Sample ID: Kitchen Faucet, 30 Seconds
Lab Sample ID: J6E0776-12
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1316



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Fountain Across Elev, First Draw
Lab Sample ID: J6E0776-13
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1320

Analytical Testing Parameters

Client Sample ID: Fountain Across Elev, 30 Seconds
Lab Sample ID: J6E0776-14
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00136, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1323

Analytical Testing Parameters

Client Sample ID: Fountain Near 212, First Draw
Lab Sample ID: J6E0776-15
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00346, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1327



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Fountain Near 212, 30 Seconds
Lab Sample ID: J6E0776-16
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00807, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1330

Analytical Testing Parameters

Client Sample ID: Room 209, First Draw
Lab Sample ID: J6E0776-17
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00145, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1334

Analytical Testing Parameters

Client Sample ID: Room 209, 30 Seconds
Lab Sample ID: J6E0776-18
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1344



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Room 105, First Draw
Lab Sample ID: J6E0776-19
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00499, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1348

Analytical Testing Parameters

Client Sample ID: Room 105, 30 Seconds
Lab Sample ID: J6E0776-20
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1351

Analytical Testing Parameters

Client Sample ID: Room 112, First Draw
Lab Sample ID: J6E0776-21
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0125, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1355



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Analytical Testing Parameters

Client Sample ID: Room 112, 30 Seconds
Lab Sample ID: J6E0776-22
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00606, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1358

Analytical Testing Parameters

Client Sample ID: Room 213, First Draw
Lab Sample ID: J6E0776-23
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00152, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1412

Analytical Testing Parameters

Client Sample ID: Room 213, 30 Seconds
Lab Sample ID: J6E0776-24
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1416

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 22.4°C





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0776

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale For Michael Fifield  
Division Manager  
05/20/2016 12:28

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Client Information		Billing/Invoice:	
Name:	Bainbridge-Guilford CSD		
Address:	18 Juliard St. Bainbridge, NY 13733		
Contact:	Howard Thompson		
Phone:	607-967-6341		
Project:	Guilford Water Lead Testing		
Quote ID:	Lead Testing	PO#: 27466	Date Req: 5-7-10
Rush TAT Bus. Days:	<2 2-5 5-7		
Carbon Copy:	Yes		
Email Results:	Yes <input checked="" type="checkbox"/> <i>hthompson@bgcsd.org</i>		
Fax Results:	Yes		

Sample Information			
Description/Location	Date	Time	Matrix Type
1 Faculty Room First Dial	5/13/16	5:00-6:00 AM	DW
2 " " 30 SEC			
3 Fountain MAIN ENTRANCE (FD)			
4 " " (30 SEC)			
5 Nurse #1 (FD)			
6 NURSE #1 (30 SEC)			
7 NURSE #2 (FD)			
8 NURSE #2 (30 SEC)			
9 Cafe Fountain (FD)			
10 " " (30 SEC)			
11 Kitchen faucet (FD)			
12 " " (30 SEC)			
13 fountain across Elev (FD)			
14 " " (30 SEC)			
15 fountain near 212 (FD)			
16 " " (30 SEC)			
17 Room 209 (FD)			
18 Room 209 30 SEC			
19 Room 105 (FD)			
20 Room 105 (30 SEC)			

Receiving Info (Lab Use Only)	
Ice:	YES NO <input checked="" type="checkbox"/>
Cooler:	YES NO <input checked="" type="checkbox"/>
Sample Temp:	22.4
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO <input checked="" type="checkbox"/>
Container Material:	
Container Size (in MI):	
Preservative:	

Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Total Lead (EPA 200.8)			1		
Plastic					
250 ml					
HNO3					

Print Name and Company	Date/Time	Comments
Howard Thompson/BG School	5/13/16 5:00 AM	
Catherine P. Hunt MLI	5/13/16 8:40	



J6E0776

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00835

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)							
Name: Bainbridge-Guilford CSD						Ice: YES NO							
Address: 18 Juliard St.						Cooler: YES NO							
Contact: Bainbridge, NY 13733						Sample Temp: 22.4							
Phone: Howard Thompson						Cooler Seal: YES NO							
Project: Guilford Water Lead Testing		PO#: 27466				Pickup: YES NO							
Quote ID: Lead Testing		Date Req: 7-10				Dropoff: C W							
Rush TAT Bus. Days: <2 2-5						Accepted? YES NO							
Carbon Copy: Yes						Container Material							
Email Results: Yes		hthompson@bgcsd.org				Container Size(in Mi)							
Fax Results: Yes						Preservative							
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data					
Description/Location	Date	Time	Matrix	Type									
1 Rm 112 First Draw	5/13/16	5:00-6:00 AM	DW	DW	1								
2 Rm 112 30 SEC													
3 Rm 213 First Draw													
4 Rm 213 30 SEC													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
Print Name and Company				Date/Time				Comments					
Sampled: Howard Thompson/BG School				5/13/16 5:00 AM									
Received: Catherine P. Hunt MLI				5/13/16 8:40									
Received:													



J6E0776

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Bainbridge-Guilford Central School District

Project Name: Greenlawn Water

Howard Thompson
18 Juliard St.
Bainbridge, NY 13733

Project / PO Number: 27466
Received: 05/12/2016 11:42
Reported: 05/19/2016 19:54

Analytical Testing Parameters

Client Sample ID: T Wing Fountain (FD)
Lab Sample ID: J6E0778-01
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0044

Analytical Testing Parameters

Client Sample ID: T Wing Fountain (30 Sec)
Lab Sample ID: J6E0778-02
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, 0.00288, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0048

Analytical Testing Parameters

Client Sample ID: Head Start Classroom (FD)
Lab Sample ID: J6E0778-03
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0051



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Head Start Classroom (30 Sec)
Lab Sample ID: J6E0778-04
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0102

Analytical Testing Parameters

Client Sample ID: Room 168 Bubbler (FD)
Lab Sample ID: J6E0778-05
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0105

Analytical Testing Parameters

Client Sample ID: Room 168 Bubbler (30 Sec)
Lab Sample ID: J6E0778-06
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0109



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Room 167 Bubbler (FD)
Lab Sample ID: J6E0778-07
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0113

Analytical Testing Parameters

Client Sample ID: Room 167 Bubbler (30 Sec)
Lab Sample ID: J6E0778-08
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0116

Analytical Testing Parameters

Client Sample ID: Room 166 Bubbler (FD)
Lab Sample ID: J6E0778-09
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0120



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Room 166 Bubbler (30 Sec)
Lab Sample ID: J6E0778-10
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0123

Analytical Testing Parameters

Client Sample ID: Faculty Room Sink (FD)
Lab Sample ID: J6E0778-11
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00815, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0127

Analytical Testing Parameters

Client Sample ID: Faculty Room Sink (30 Sec)
Lab Sample ID: J6E0778-12
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0130



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Nurse Sink #1 (FD)
Lab Sample ID: J6E0778-13
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00762, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0134

Analytical Testing Parameters

Client Sample ID: Nurse Sink #1 (30 Sec)
Lab Sample ID: J6E0778-14
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0145

Analytical Testing Parameters

Client Sample ID: Nurse Sink #2 (FD)
Lab Sample ID: J6E0778-15
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00122, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0148





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Nurse Sink #2 (30 Sec)
Lab Sample ID: J6E0778-16
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0152

Analytical Testing Parameters

Client Sample ID: Classroom 150 Bubbler (FD)
Lab Sample ID: J6E0778-17
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00115, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0155

Analytical Testing Parameters

Client Sample ID: Classroom 150 Bubbler (30 Sec)
Lab Sample ID: J6E0778-18
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0159



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Classroom 157 Bubbler (FD)
Lab Sample ID: J6E0778-19
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, 0.00604, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0213

Analytical Testing Parameters

Client Sample ID: Classroom 157 Bubbler (30 Sec)
Lab Sample ID: J6E0778-20
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0217

Analytical Testing Parameters

Client Sample ID: Classroom 156 Bubbler (FD)
Lab Sample ID: J6E0778-21
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, 0.00218, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0227



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Classroom 156 Bubbler (30 Sec)
Lab Sample ID: J6E0778-22
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0231

Analytical Testing Parameters

Client Sample ID: Classroom 152 Bubbler (FD)
Lab Sample ID: J6E0778-23
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00427, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0234

Analytical Testing Parameters

Client Sample ID: Classroom 152 Bubbler (30 Sec)
Lab Sample ID: J6E0778-24
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0238



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Classroom 155 Bubbler (FD)
Lab Sample ID: J6E0778-25
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00594, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0242

Analytical Testing Parameters

Client Sample ID: Classroom 155 Bubbler (30 Sec)
Lab Sample ID: J6E0778-26
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0245

Analytical Testing Parameters

Client Sample ID: Classroom 153 Bubbler (FD)
Lab Sample ID: J6E0778-27
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0454, 0.00100, mg/L, g, 05/17/16 1230, 05/18/16 0249



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Classroom 153 Bubbler (30 Sec)
Lab Sample ID: J6E0778-28
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0252

Analytical Testing Parameters

Client Sample ID: Classroom 154 Bubbler (FD)
Lab Sample ID: J6E0778-29
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0256

Analytical Testing Parameters

Client Sample ID: Classroom 154 Bubbler (30 Sec)
Lab Sample ID: J6E0778-30
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, 0.00182, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0259



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Near Gang (FD)
Lab Sample ID: J6E0778-31
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0310

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Near Gang (30 Sec)
Lab Sample ID: J6E0778-32
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0314

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Near Cafe (FD)
Lab Sample ID: J6E0778-33
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0317



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Near Cafe (30 Sec)
Lab Sample ID: J6E0778-34
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0321

Analytical Testing Parameters

Client Sample ID: Kitchen Pot Sink #1 (FD)
Lab Sample ID: J6E0778-35
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0324

Analytical Testing Parameters

Client Sample ID: Kitchen Pot Sink #1 (30 Sec)
Lab Sample ID: J6E0778-36
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00305, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0328



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Kitchen Pot Sink #2 (FD)
Lab Sample ID: J6E0778-37
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0332

Analytical Testing Parameters

Client Sample ID: Kitchen Post Sink #2 (30 Sec)
Lab Sample ID: J6E0778-38
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0335

Analytical Testing Parameters

Client Sample ID: Boys Locker Room Fountain (FD)
Lab Sample ID: J6E0778-39
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev.5.4, Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0357





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Boys Locker Room Fountain (30 Sec)
Lab Sample ID: J6E0778-40
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0400

Analytical Testing Parameters

Client Sample ID: Girls Locker Room Fountain (FD)
Lab Sample ID: J6E0778-41
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0404

Analytical Testing Parameters

Client Sample ID: Girls Locker Room Fountain (30 Sec)
Lab Sample ID: J6E0778-42
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0407



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Wrestling Room Fountain (FD)
Lab Sample ID: J6E0778-43
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0411

Analytical Testing Parameters

Client Sample ID: Wrestling Room Fountain (30 Sec)
Lab Sample ID: J6E0778-44
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0415

Analytical Testing Parameters

Client Sample ID: Outside Fountain Truckbay (FD)
Lab Sample ID: J6E0778-45
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00453, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0418



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0778

Analytical Testing Parameters

Client Sample ID: Outside Fountain Truckbay (30 Sec)
Lab Sample ID: J6E0778-46
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/17/16 1230, 05/18/16 0422

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
g: Result fails applicable NYS drinking water standards
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 23.4°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes/No, Item, Yes/No. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice, Containers Intact, Preservation Correct.

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield
Division Manager
05/19/2016 19:54

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

Samples must be returned on ice  
 MNY Workorder #

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

Client Information		Billing/Invoice:	
Name:	Bainbridge-Guilford CSD		
Address:	18 Juliard St. Bainbridge, NY 13733		
Contact:	Howard Thompson		
Phone:	607-967-6341		
Project:	Greenlawn Water		
Quote ID:	Lead Testing	PO#: 27466	Date Req.:
Rush TAT Bus. Days:	< 2-5 5-7 (7-10)		
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
Email Results:		athompson@bgcsd.org	

Sample Information			Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
1 T WING FOUNTAIN (FD)	5/12/16	5:00 - 6:00 AM	DW		1	
2 " " (30 sec)						
3 Headstart Classroom (FD)						
4 " " (30 sec)						
5 Rm 168 Bobbler (FD)						
6 " " (30 sec)						
7 Rm 167 Bobbler (FD)						
8 Rm 167 Bobbler (30 sec)						
9 Rm 166 Bobbler (FD)						
10 Rm 166 Bobbler (30 sec)						
11 Faculty room sink (FD)						
12 " " (30 sec)						
13 Nurse Sink #1 (FD)						
14 Nurse Sink #1 (30 sec)						
15 Nurse Sink #2 (FD)						
16 Nurse Sink #2 (30 sec)						
17 Classroom 150 Bobbler (FD)						
18 " " (30 sec)						
19 " 157 " (FD)						
20 " 157 " (30 sec)						

Accepted?	YES NO
Container Material	
Container Size (in ml)	
Preservative	
Sample Temp:	23.2
Cooler Seat:	YES NO
Pickup:	YES NO
Dropoff:	C W
Ice:	YES NO
Cooler:	YES NO

Sampled:	Howard Thompson / RG School	Date/Time	5/12/16 5:00 AM
Received:	Jennifer Walker MLI	Date/Time	5/12/16 11:42
Received:			



J6E0778

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
Corland NY 13045  
Phone:(607)753-3403 Fax:(607)753-3415  
NY #10786, EPA #NY00835

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Bainbridge-Guilford CSD					Ice:	YES NO
Address:	18 Juliand St.					Cooler:	YES NO
Contact:	Bainbridge, NY 13733					Sample Temp:	
Phone:	Howard Thompson					Cooler Seal:	YES NO
Project:	607-967-6341					Pickup:	YES NO
Quote ID:	Greenlawn Water					Dropoff:	C W
Rush TAT Bus. Days:	Lead Testing	PO#:	27466			Accepted?	YES NO
Carbon Copy:	Yes	Date Req.:				Container Material	
Email Results:	Yes					Container Size(in Ml)	
Fax Results:	Yes					Preservative	

Sample Information		Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
1	Classroom 156 Robbler (FD)	5/12/16	5:06 AM	DW	DW	1	
2	" " " (30 sec)						
3	Classroom 152 " (FD)						
4	" " " (30 sec)						
5	Classroom 155 " (FD)						
6	" " " (30 sec)						
7	" " " (FD)						
8	" " " (30 sec)						
9	" " " (FD)						
10	" " " (30 sec)						
11	Drinking fountain near gym (FD)						
12	" " " (30 sec)						
13	" " " (FD)						
14	" " " (30 sec)						
15	Kitchen pot sink #1 (FD)						
16	" " " (30 sec)						
17	Kitchen pot sink #2 (FD)						
18	" " " (30 sec)						
19	Boys locker room fountain (FD)						
20	" " " (30 sec)						

Print Name and Company	Date/Time	Comments
Howard Thompson / BG School	5/12/16 5:00 AM	
Jennifer Walker MUI	5/12/16 5:10 AM	



J6E0778

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)					
Name:	Bainbridge-Guilford CSD					Ice:	YES NO				
Address:	18 Juliard St. Bainbridge, NY 13733					Cooler:	YES NO				
Contact:	Howard Thompson					Sample Temp:	YES NO				
Phone:	607-967-6341					Cooler Seal:	YES NO				
Project:	Greenlawn Water					Pickup:	YES NO				
Quote ID:	Lead Testing	PO#:	27466			Dropoff:	C W				
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO				
Carbon Copy:	Yes					Container Material					
Email Results:	Yes <input checked="" type="checkbox"/> <i>hthompson@sgesd.org</i>					Container Size (in Mi)					
Fax Results:	Yes					Preservative					
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data			
Description/Location	Date	Time	Matrix Type								
1 Girls lockers - fountain (FD)			DW								
2 " " (30 sec)											
3 Adresting Room fountain (FD)											
4 " " (30 sec)											
5 Outside fountain trackway (FD)											
6 " " (30 sec)											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
Print Name and Company				Date/Time				Comments			
Sampled: Howard Thompson / BG School				5/24/16 5:00 AM							
Received: Jennifer Walker MNY				Jennifer Walker 5/24/16 11:40 AM							
Received:											



J6E0778

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E1288

Bainbridge-Guilford Central School District

Project Name: Lead Testing

Howard Thompson
18 Juliard St.
Bainbridge, NY 13733

Project / PO Number: 27466
Received: 05/31/2016 10:16
Reported: 06/16/2016 22:09

Analytical Testing Parameters

Client Sample ID: Rm 135 FD
Lab Sample ID: J6E1288-01
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/31/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.005, 0.001, mg/L, 06/07/16 0925, 06/10/16 1918

Analytical Testing Parameters

Client Sample ID: Rm 135 30 sec
Lab Sample ID: J6E1288-02
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/31/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0034, 0.001, mg/L, 06/07/16 0925, 06/10/16 1921

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Description, Yes, Containers Intact, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc. Dayville (NY 11549)
NY Lab ID No: 11549

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E1288

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield  
Division Manager  
06/16/2016 22:09

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*



3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. CHAIN OF CUSTODY



J6E1288

Client Information		Billing/Invoices		Analysis Requested				Receiving Info (Lab Use Only)	
Name: <u>Bow Bridge - Cortland</u>								Ice: <u>YES</u> <u>NO</u>	
Address: <u>18 Deland St</u>								Cooler: <u>YES</u> <u>NO</u>	
Contact: <u>Howard Thompson</u>								Sample Temp:	
Phone: <u>607 747 6323</u>								Cooler Seal: <u>YES</u> <u>NO</u>	
Project: <u>Overlawn Research</u>								Pickup: <u>YES</u> <u>NO</u>	
Quote ID: <u>NY-146</u>		PO#: <u>87466</u>						Dropoff: <u>C</u> <u>W</u>	
Rush TAT Bus. Days: <u>2-5</u> <u>5-7</u> <u>7-10</u>		Date Req:						Accepted? <u>YES</u> <u>NO</u>	
Carbon Copy: <u>Yes</u>								Container Material	
Email Results: <u>Yes</u> <u>hthompson@bycsd.ny</u>								Container size(in MI)	
Fax Results: <u>Yes</u>								Preservative	
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data	
Description/Location	Date	Time	Initial	Matrix Type					
1 <u>Rm 135 FD</u>	<u>5/31</u>	<u>6:00AM MT</u>	<u>MT</u>	<u>DW</u> <u>G</u>	<u>1</u>				<u>(Re test and</u>
2 <u>Rm 135 30 sec</u>	<u>5/31</u>	<u>6:00AM MT</u>	<u>MT</u>	<u>DW</u> <u>G</u>	<u>1</u>				<u>discard)</u>
3									
4									
5									
6									
7									
8									
Print Name and Company				Signature		Date/Time		Comments	
<u>Howard Thompson</u>				<u>Howard Thompson</u>		<u>5/31/16 10:16</u>			
Sampled:									
Received: <u>Jennifer Walker MTS</u>									
Received:									
Received:									

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Bainbridge-Guilford Central School District

Project Name: Lead Testing

Howard Thompson  
18 Juliard St.  
Bainbridge, NY 13733

Project / PO Number: 27466  
Received: 05/11/2016 09:26  
Reported: 05/25/2016 20:02

Analytical Testing Parameters

Client Sample ID: ANNEX FACULTY (FIRST DRAW)  
Lab Sample ID: J6E0723-01  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/11/16  
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.0119	0.00100	mg/L		05/19/16 1030	05/19/16 2000

Analytical Testing Parameters

Client Sample ID: ANNEX FACULTY (30 SECOND)  
Lab Sample ID: J6E0723-02  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/11/16  
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.00407	0.00100	mg/L		05/19/16 1030	05/19/16 2003

Analytical Testing Parameters

Client Sample ID: ANNEX DRINKING FOUNTAIN (FD)  
Lab Sample ID: J6E0723-03  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/11/16  
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.00666	0.00100	mg/L		05/19/16 1030	05/19/16 2007



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: ANNEX DRINKING FOUNTAIN (30 SEC)
Lab Sample ID: J6E0723-04
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00366, 0.00100, mg/L, 05/19/16 1030, 05/19/16 2010

Analytical Testing Parameters

Client Sample ID: BOTTLE SINK MPR (FD)
Lab Sample ID: J6E0723-05
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1030, 05/19/16 2014

Analytical Testing Parameters

Client Sample ID: BOTTLE SINK MPR (30 SEC)
Lab Sample ID: J6E0723-06
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1030, 05/19/16 2017



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #1 (FD)
Lab Sample ID: J6E0723-07
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1030, 05/19/16 2021

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #1 (30 SEC)
Lab Sample ID: J6E0723-08
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2024

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #2 (FD)
Lab Sample ID: J6E0723-09
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2046



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #2 (30 SEC)
Lab Sample ID: J6E0723-10
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2049

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #3 (FD)
Lab Sample ID: J6E0723-11
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2053

Analytical Testing Parameters

Client Sample ID: KITCHEN POT SINK #3 (30 SEC)
Lab Sample ID: J6E0723-12
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2056



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, VENDING (FD)
Lab Sample ID: J6E0723-13
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2100

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, VENDING (30 SEC)
Lab Sample ID: J6E0723-14
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2103

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, NEAR 105 (FD)
Lab Sample ID: J6E0723-15
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2107



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, NEAR 105 (30 SEC)
Lab Sample ID: J6E0723-16
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2110

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, MAIN OFFICE (FD)
Lab Sample ID: J6E0723-17
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2114

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN, MAIN OFFICE (30 SEC)
Lab Sample ID: J6E0723-18
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2124



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: NURSES OFFICE (FIRST DRAW)
Lab Sample ID: J6E0723-19
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2128

Analytical Testing Parameters

Client Sample ID: NURSES OFFICE (30 SEC)
Lab Sample ID: J6E0723-20
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2131

Analytical Testing Parameters

Client Sample ID: FACULTY ROOM (FIRST DRAW)
Lab Sample ID: J6E0723-21
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2135





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: FACULTY ROOM (30 SEC)
Lab Sample ID: J6E0723-22
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2139.

Analytical Testing Parameters

Client Sample ID: ROOM 108 #1 (FD)
Lab Sample ID: J6E0723-23
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00123, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2142.

Analytical Testing Parameters

Client Sample ID: ROOM 108 #1 (30 SEC)
Lab Sample ID: J6E0723-24
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2146.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: ROOM 108 #2 (FD)
Lab Sample ID: J6E0723-25
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00164, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2149.

Analytical Testing Parameters

Client Sample ID: ROOM 108 #2 (30 SEC)
Lab Sample ID: J6E0723-26
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2153.

Analytical Testing Parameters

Client Sample ID: ROOM 108 #3 (FD)
Lab Sample ID: J6E0723-27
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00112, 0.00100, mg/L, 05/19/16 1100, 05/19/16 2156.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: ROOM 108 #3 (30 SEC)
Lab Sample ID: J6E0723-28
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2207

Analytical Testing Parameters

Client Sample ID: ROOM 108 #4 (FD)
Lab Sample ID: J6E0723-29
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00434, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2221

Analytical Testing Parameters

Client Sample ID: ROOM 108 #4 (30 SEC)
Lab Sample ID: J6E0723-30
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2225



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 109 (FD)
Lab Sample ID: J6E0723-31
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2228

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 109 (30 SEC)
Lab Sample ID: J6E0723-32
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2232

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 115 (FD)
Lab Sample ID: J6E0723-33
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2235



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 115 (30 SEC)
Lab Sample ID: J6E0723-34
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2239

Analytical Testing Parameters

Client Sample ID: ROOM 219 #1 (FD)
Lab Sample ID: J6E0723-35
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2249

Analytical Testing Parameters

Client Sample ID: ROOM 219 #1 (30 SEC)
Lab Sample ID: J6E0723-36
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2253



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: ROOM 219 #2 (FD)
Lab Sample ID: J6E0723-37
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2257

Analytical Testing Parameters

Client Sample ID: ROOM 219 #2 (30 SEC)
Lab Sample ID: J6E0723-38
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/20/16 0900, 05/20/16 1242

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN ACROSS 220 (FD)
Lab Sample ID: J6E0723-39
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2300



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN ACROSS 220 (30 SEC)
Lab Sample ID: J6E0723-40
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2304

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 215 (FD)
Lab Sample ID: J6E0723-41
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2307

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 215 (30 SEC)
Lab Sample ID: J6E0723-42
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2311



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 229 (FD)
Lab Sample ID: J6E0723-43
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2314

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 229 (30 SEC)
Lab Sample ID: J6E0723-44
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2318

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 209 (FD)
Lab Sample ID: J6E0723-45
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2321





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 209 (30 SEC)
Lab Sample ID: J6E0723-46
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2332

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 206 (FD)
Lab Sample ID: J6E0723-47
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2336

Analytical Testing Parameters

Client Sample ID: DRINKING FOUNTAIN NEAR 206 (30 SEC)
Lab Sample ID: J6E0723-48
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2339



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: ROOM 106 (FD)
Lab Sample ID: J6E0723-49
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2353

Analytical Testing Parameters

Client Sample ID: ROOM 106 (30 SEC)
Lab Sample ID: J6E0723-50
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00129, 0.00100, mg/L, 05/19/16 1400, 05/19/16 2357

Analytical Testing Parameters

Client Sample ID: WRESTLING ROOM (FD)
Lab Sample ID: J6E0723-51
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/20/16 0900, 05/20/16 1246



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0723

Analytical Testing Parameters

Client Sample ID: WRESTLING ROOM (30 SEC)
Lab Sample ID: J6E0723-52
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/11/16
Collection Time: 06:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.00100, mg/L, 05/20/16 0900, 05/20/16 1249

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 19.9°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes/No, Item, Yes/No. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice, Containers Intact, Preservation Correct.

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
05/25/2016 20:02

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

Samples must be returned on ice  
 MNY Workorder # Pj 1063

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY009935

Client Information		Billing/Invoice:	
Name:	Bainbridge-Guilford CSD		
Address:	18 Juliard St. Bainbridge, NY 13733		
Contact:	Howard Thompson		
Phone:	607-967-6341		
Project:	High School Water	PO#: 27466	
Quote ID:	Lead Testing	Date Req.:	
Rush TAT Bus. Days:	< 2-5 5-7 (7-10)		
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
Email Results: <input checked="" type="checkbox"/> Yes		hthompson@bgesd.org	

Sample Information			Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
1 Annex faculty (first Draw)	5/14/16	5:6 AM	DW	DW	1	Annex for cups dirty
2 " " (30 second)						
3 Annex Drinking fount.(FD)						
4 " " " (30 sec)						
5 Bottle Sink MPR, (F.D)						
6 " " " (30 sec)						
7 Kitchen Pot sink #1 (FD)						
8 " " " #1 (30 sec)						
9 " " " #2 (FD)						
10 " " " #2 (30 sec)						
11 " " " #3 (FD)						
12 " " " #3 (30 sec)						
13 Drinking fountain, vending (FD)						
14 " " " (30 sec)						fountain water was hot!
15 Drinking fountain near 105 (FD)						
16 " " " (30 sec)						
17 Drinking fountain main office (FD)						
18 " " " (30 sec)						
19 Nurses Office (first Draw)						
20 Nurses Office (30 second)						

Accepted?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Container Material	
Container Size (in ML)	
Preservative	

Ice:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Cooler:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Sample Temp:	16.9
Cooler Seat:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Pickup:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Dropoff:	C W

Date/Time	5/14/16 5:00 AM
Print Name and Company	Gennifer Walker / BG School
Comments	



J6E0723

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**


**Samples must be returned on ice**  
 MNY Workorder # Page 3 of 3

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

Client Information		Billing/Invoice:	
Name:	Bainbridge-Guilford CSD	PO#:	27466
Address:	18 Juliard St. Bainbridge, NY 13733	Date Req.:	
Contact:	Howard Thompson	Carbon Copy: Yes	
Phone:	607-967-6341	Email Results: <input checked="" type="checkbox"/> Yes	
Project:	High School Water	Fax Results: <input checked="" type="checkbox"/> Yes	
Quote ID:	Lead Testing	Rush TAT Bus. Days: <2 2-5 5-7 (7-10)	

Email Results:  Yes hthompson@bgcsd.org

Sample Information		Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
Description/Location							
1 Drinking fountain near 215 (FD)		5/11/16	5:06 AM	DW	DW	1	Drinking fountain { WAS WARM
2 " " " (30 sec)							
3 Drinking fountain near 229 (FD)							
4 " " " (30 sec)							
5 Drinking fountain near 209 (FD)							
6 " " " (30 sec)							
7 Drinking fountain near 206 (FD)							
8 " " " 206 (30 sec)							
9 Room 106 (FD)							
10 " " (30, SEC)							
11 Wrestling Area (FD)							
12 Wrestling Rm (30 sec)							
13							
14							
15							
16							
17							
18							
19							
20							



Sampled:	Howard Thompson / BG School	Date/Time:	5/11/16 5:00 AM
Received:	Jennifer Walker met	Date/Time:	5/11/16 9:26
Received:	Jennifer Walker		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0779

Bainbridge-Guilford Central School District

Project Name: Bus Maintenance

Howard Thompson  
18 Juliard St.  
Bainbridge, NY 13733

Project / PO Number: 27466  
Received: 05/12/2016 11:42  
Reported: 05/20/2016 13:01

Analytical Testing Parameters

Client Sample ID: Fountain, First Draw  
Lab Sample ID: J6E0779-01  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/12/16  
Collection Time: 07:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.00111	0.00100	mg/L		05/18/16 1000	05/18/16 1426

Analytical Testing Parameters

Client Sample ID: Fountain, 30 Sec  
Lab Sample ID: J6E0779-02  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/12/16  
Collection Time: 07:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.00259	0.00100	mg/L		05/18/16 1000	05/18/16 1430

Analytical Testing Parameters

Client Sample ID: Driver's Room, First Draw  
Lab Sample ID: J6E0779-03  
Sample Type: Grab

Collected By: Howard Thompson  
Collection Date: 05/12/16  
Collection Time: 07:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Metals via ICP-MS per EPA 200.8 Rev.5.4	Result	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev.5.4						
Lead	0.00609	0.00100	mg/L		05/18/16 1000	05/18/16 1433



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6E0779

Analytical Testing Parameters

Client Sample ID: Driver's Room, 30 Sec
Lab Sample ID: J6E0779-04
Sample Type: Grab

Collected By: Howard Thompson
Collection Date: 05/12/16
Collection Time: 07:00

Analyses Subcontracted to: Envirotest Laboratories, Inc. (EPA NY00049)

Table with 7 columns: Metals via ICP-MS per EPA 200.8 Rev.5.4, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00267, 0.00100, mg/L, 05/18/16 1000, 05/18/16 1437

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 23.3°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes/No, Item, Yes/No. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice, Containers Intact, Preservation Correct.

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale For Michael Fifield
Division Manager
05/20/2016 13:01

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.



